

Energy Tips

Tip Sheet #1 • May 2002



Process Heat



Motors



Compressed Air

Payback Guidelines

Process temperature is customarily used as a rough indication of where air preheating will be cost effective. Processes operating above 1,600° F are generally good candidates, while preheated air is difficult to justify on processes operating below 1,000° F. Those in the 1,000 to 1,600° F range may still be good candidates but must be evaluated on a case-by-case basis.

These guidelines are not ironclad. Financial justification is based on energy (or Btu) saved, rather than on temperature differential. If a low temperature process has a high enough exhaust gas flow, energy savings may still exist, even though the exhaust gas temperature is lower than 1,000° F.

References

1. *Combustion Technology Manual*. Published by Industrial Heating Equipment Association (IHEA), Arlington, Virginia 22209.
2. *Maintenance and Adjustment Manual for Natural Gas and No. 2 Fuel Oil Burners*. Technical Information Center, Department of Energy.
3. *Handbook of Applied Thermal Design*, edited by Eric C. Guyer. Published by McGraw Hill Book Company.

Process Heating Tip Sheet information adapted from material provided by the E3M, Inc. and reviewed by the DOE Best Practices Process Heating Steering Committee. For additional information on Process Heating efficiency measures, contact the OIT Clearinghouse at (800) 862-2086.



Preheated Combustion Air

For fuel-fired industrial heating processes, one of the most potent ways to improve efficiency and productivity is to preheat the combustion air going to the burners. The source of this heat energy is the exhaust gas stream, which leaves the process at elevated temperatures. A heat exchanger, placed in the exhaust stack or ductwork, can extract a large portion of the thermal energy in the flue gases and transfer it to the incoming combustion air. Recycling heat this way will reduce the amount of the purchased fuel needed by the furnace.

Many processes produce dirty or corrosive exhaust gases that will plug or attack heat exchangers. Some exchangers are more resistant to these conditions than others, so if your process is not a clean one, do not give up without investigating all the options. When discussing it with potential vendors, be sure to have a detailed analysis of the troublesome materials in your exhaust gas stream.

Fuel savings for different process temperatures can be found in the table below and can be used to estimate reductions in energy costs.

Percent Fuel Savings Gained from Using Preheated Combustion Air

Furnace Exhaust Temperature, °F	Preheated Air Temperature, °F					
	600	800	1,000	1,200	1,400	1,600
1,000	13	18	—	—	—	—
1,200	14	19	23	—	—	—
1,400	15	20	24	28	—	—
1,600	17	22	26	30	34	—
1,800	18	24	28	33	37	40
2,000	20	26	31	35	39	43
2,200	23	29	34	39	43	47
2,400	26	32	38	43	47	51

Fuel: Natural gas at 10 percent excess air

Source: IHEA Combustion Technology Manual (see references)

There are two types of air preheaters: recuperators and regenerators. Recuperators are gas-to-gas heat exchangers placed on the furnace stack. Internal tubes or plates transfer heat from the outgoing exhaust gas to the incoming combustion air while keeping the two streams from mixing. Recuperators are available in a wide variety of styles, flow capacities, and temperature ranges. Regenerators include two or more separate heat storage sections. Flue gases and combustion air take turns flowing through each regenerator, alternately heating the storage medium and then withdrawing heat from it. For uninterrupted operation, at least two regenerators and their associated burners are required: one regenerator is needed to fire the furnace while the other is recharging.

Payback Period = (Cost of combustion air preheating system, obtained from the supplier or contractor) ÷ (Reduction in fuel usage, Million Btu/hr x Number of operating hours per year x Cost of fuel per Million Btu)

Example

A furnace operates at 1600°F for 8,000 hours per year at an average of 10 million British thermal units (MMBtu) per hour using ambient temperature combustion air. At \$5 per

MMBtu, annual energy cost is \$800,000. Use of preheated air at 800° F will result in 22 percent fuel savings, or \$176,000 annually. The preheated air system installation is estimated to cost \$200,000 to \$250,000, with a payback period of 13.6 months to 17 months, or an annual return on investment (ROI) of 88 percent to 70 percent.

Suggested Actions

- Using current or projected energy costs, estimate preheated air savings with this example or the Process Heating Assessment and Survey Tool (PHAST) available from the Department of Energy's Office of Industrial Technologies.
- Contact furnace or combustion system suppliers to calculate payback period or ROI.



BestPractices is part of the Office of Industrial Technologies Industries of the Future strategy, which helps the country's most energy-intensive industries improve their competitiveness. BestPractices brings together the best-available and emerging technologies and practices to help companies begin improving energy efficiency, environmental performance, and productivity right now.

BestPractices emphasizes plant systems, where significant efficiency improvements and savings can be achieved. Industry gains easy access to near-term and long-term solutions for improving the performance of motor, steam, compressed air, and process heating systems. In addition, the Industrial Assessment Centers provide comprehensive industrial energy evaluations to small and medium-size manufacturers.

FOR ADDITIONAL INFORMATION, PLEASE CONTACT:

Peter Salmon-Cox
Office of Industrial Technologies
Phone: (202) 586-2380
Fax: (202) 586-9234
Peter.Salmon-Cox@hq.doe.gov
www.oit.doe.gov/bestpractices

OIT Clearinghouse
Phone: (800) 862-2086
Fax: (360) 586-8303
clearinghouse@ee.doe.gov

Please send any comments, questions, or suggestions to webmaster.oit@ee.doe.gov

Visit our home page at www.oit.doe.gov

Office of Industrial Technologies
Energy Efficiency
and Renewable Energy
U.S. Department of Energy
Washington, DC 20585-0121

DOE/GO-102002-1551
May 2002
Process Heat Tip Sheet #1

About DOE's Industrial Technologies Program

The Industrial Technologies Program, through partnerships with industry, government, and non-governmental organizations, develops and delivers advanced energy efficiency, renewable energy, and pollution prevention technologies for industrial applications. The Industrial Technologies Program is part of the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy. DOE encourages industry-wide efforts to boost resource productivity through a strategy called Industries of the Future (IOF). IOF focuses on the following nine energy- and resource-intensive industries:

- Agriculture
- Aluminum
- Chemicals
- Forest Products
- Glass
- Metal Casting
- Mining
- Petroleum
- Steel

The Industrial Technologies Program's BestPractices offers a wide variety of resources to industrial partners that cover motor, steam, compressed air, and process heating systems. For example, BestPractices software can help you decide whether to replace or rewind motors (MotorMaster+), assess the efficiency of pumping systems (PSAT), compressed air systems (AirMaster+), steam systems (Steam Scoping Tool), or determine optimal insulation thickness for pipes and pressure vessels (3E Plus). Training is available to help you or your staff learn how to use these software programs and learn more about industrial systems. Workshops are held around the country on topics such as "Capturing the Value of Steam Efficiency," "Fundamentals and Advanced Management of Compressed Air Systems," and "Motor System Management." Available technical publications range from case studies and tip sheets to sourcebooks and market assessments. The *Energy Matters* newsletter, for example, provides timely articles and information on comprehensive energy systems for industry. You can access these resources and more by visiting the BestPractices Web site at www.oit.doe.gov/bestpractices or by contacting the Industrial Technologies Clearinghouse at 800-862-2086 or via email at clearinghouse@ee.doe.gov.