

United States Environmental Protection Agency
Region 10
1200 Sixth Avenue
Seattle, Washington 98101

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, 33 U.S.C. §1251 et seq., as amended by the Water Quality Act of 1987, P.L. 100-4, the "Act",

City of Wilder
P.O. Box 687
Wilder, Idaho 83676

is authorized to discharge from a wastewater treatment facility located in Sagle, Idaho, at the approximate location described below:

| <u>Outfall</u> | <u>Receiving Water</u> | <u>Latitude</u> | <u>Longitude</u> |
|----------------|------------------------|-----------------|------------------|
| 001 | Wilder Ditch Drain | 43° 40' 39" N | 116° 54' 06" W |

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective

This permit and the authorization to discharge shall expire at midnight,

The permittee shall reapply for a permit reissuance on or before _____, 180 days before the expiration of this permit if the permittee intends to continue operations and discharges at the facility beyond the term of this permit.

Signed this _____ day of _____

Michael F. Gearheard, Director
Office of Water and Watersheds
U.S. Environmental Protection Agency, Region 10

TABLE OF CONTENTS

| | |
|---|-----------|
| Cover Sheet--Issuance and Expiration Dates | |
| Schedule of Submissions. | 4 |
| I. SPECIFIC LIMITATIONS AND MONITORING REQUIREMENTS | 5 |
| A. Effluent Limitations and Monitoring Requirements. | 5 |
| B. Schedule of Compliance | 6 |
| C. Surface Water Monitoring Requirements | 6 |
| D. Operation and Maintenance Plan | 8 |
| E. Quality Assurance Requirements | 8 |
| II. MONITORING, RECORDING AND REPORTING REQUIREMENTS | 9 |
| A. Representative Sampling (Routine and Non-Routine Discharges) | 9 |
| B. Reporting of Monitoring Results | 10 |
| C. Monitoring Procedures | 10 |
| D. Additional Monitoring by Permittee | 10 |
| E. Records Contents | 11 |
| F. Retention of Records | 11 |
| G. Twenty-four Hour Notice of Noncompliance Reporting | 11 |
| H. Other Noncompliance Reporting | 12 |
| I. Notice of New Introduction of Pollutants | 12 |
| J. Compliance Schedule | 13 |
| III. COMPLIANCE RESPONSIBILITIES | 13 |
| A. Duty to Comply | 13 |
| B. Penalties for Violations of Permit Conditions | 13 |
| C. Need to Halt or Reduce Activity not a Defense | 15 |
| D. Duty to Mitigate | 15 |
| E. Proper Operation and Maintenance | 15 |
| F. Bypass of Treatment Facilities | 16 |
| G. Upset Conditions | 17 |
| H. Toxic Pollutants | 17 |
| I. Planned Changes | 18 |
| J. Anticipated Noncompliance | 18 |
| IV. GENERAL PROVISIONS | 18 |
| A. Permit Actions | 18 |
| B. Duty to Reapply | 18 |
| C. Duty to Provide Information | 18 |
| D. Other Information | 19 |

| | | |
|----|-------------------------------|----|
| E. | Signatory Requirements | 19 |
| F. | Availability of Reports | 20 |
| G. | Inspection and Entry | 20 |
| H. | Property Rights | 21 |
| I. | Transfers | 21 |
| J. | State Laws | 21 |
| K. | Reopener | 21 |
| V. | DEFINITIONS | 21 |

The following is a summary of some of the items the permittee must complete and/or submit to EPA during the term of this permit:

| <u>Item</u> | <u>Due Date</u> |
|---------------------------------------|---|
| 1. Discharge Monitoring Reports (DMR) | DMRs are due monthly and must be postmarked by the 15 th day of the month following the monitoring month (see Part II.B) |
| 2. Operation and Maintenance Plan | The Plan must be developed and implemented 180 days after the effective date of the permit (see I.C.). The Plan must be kept on site. |
| 3. Quality Assurance Plan | The Plan must be developed and implemented 180 days after the effective date of the permit (see Part I.D.). The Plan must be kept on site. |
| 4. Report of Progress | The Report must be submitted 12 months after the effective date of the permit (see I.B.). |
| 5. Chlorine Effluent Limits | Compliance with chlorine effluent limits must be achieved by 2 years from permit effective date (see Section I.B.). |
| 6. NPDES Application Renewal | The application must be submitted 180 days before the expiration date of the permit (see IV.B.). |
| 7. Surface Water Monitoring Report | The Report must be submitted with the NPDES Application Renewal (180 days before the expiration date of the permit). |

I. SPECIFIC LIMITATIONS AND MONITORING REQUIREMENTS

A. Effluent Limitations and Monitoring Requirements.

1. During the period beginning on the effective date of this permit the Permittee is authorized to discharge wastewater from Outfall 001 to the Wilder Ditch Drain provided the discharge meets the limitations and monitoring requirements set forth herein. This permit does not authorize the discharge of any waste streams, including spills and other unintentional or non-routine discharges of pollutants, that are not part of the normal operation of the facility as disclosed in the permit application.

Table 1: Effluent Limitations and Monitoring Requirements

| Parameter | Effluent Limitations | | | | Monitoring Requirements | | |
|---|-----------------------|----------------------|---------------------|-----------------------------|-------------------------|------------------|------------------|
| | Average Monthly Limit | Average Weekly Limit | Maximum Daily Limit | Instantaneous Maximum Limit | Sample Location | Sample Frequency | Sample Type |
| Flow, mgd | --- | --- | --- | --- | Effluent | continuous | recording |
| Biochemical Oxygen Demand (BOD ₅) | 30 mg/l | 45 mg/l | --- | --- | Influent and Effluent | 1/month | 8-hour composite |
| | 62.5 lbs/day | 94 lbs/day | --- | --- | | | |
| Total Suspended Solids (TSS) | 30 mg/l | 45 mg/l | --- | --- | Influent and Effluent | 1/month | 8-hour composite |
| | 62.5 | 94 lbs/day | --- | --- | | | |
| <i>E. coli</i> ^{1,2} | 126/100 ml | --- | --- | 576/100 ml | Effluent | 5/month | grab |
| Total Residual Chlorine ⁴ | 0.007 mg/l | --- | 0.018 mg/l | --- | Effluent | 1/week | grab |
| | 0.015 lbs/day | --- | 0.038 lbs/day | --- | | | |
| Dissolved Oxygen, mg/l ³ | --- | --- | --- | --- | Effluent | 1/month | grab |
| Total Phosphorus, mg/l ³ | --- | --- | --- | --- | Effluent | 1/month | 8-hour composite |
| Total Inorganic Nitrogen, mg/l ³ | --- | --- | --- | --- | Effluent | 1/month | 8-hour composite |
| Total Ammonia as N, mg/l ³ | --- | --- | --- | --- | Effluent | 1/month | 8-hour composite |
| Temperature, C° ³ | --- | --- | --- | --- | Effluent | 1/month | grab |

1. The average monthly *E. coli* count must not exceed a geometric mean of 126/100 ml based on a minimum of five samples taken every 3-5 days within a calendar month. See Part V for definition of geometric mean.
2. Reporting is required within 24 hours of a maximum daily limit or instantaneous maximum limit violation. See Part II.G
3. Monitoring shall be conducted once per month for a period of two (2) years
4. The average monthly and maximum daily concentration limits for chlorine are not quantifiable using EPA approved test methods. The permittee will be in compliance with the effluent limits for chlorine provided the average monthly and maximum daily total chlorine residual levels are at or below the compliance evaluation level of 0.1 mg/l, with a loading at or below 0.21 lbs/day.

2. The pH range shall be between 6.5 - 9.0 standard units. The Permittee shall monitor for pH once per week. Sample analysis shall be conducted on a grab sample from the effluent.
3. There shall be no discharge of floating solids, visible foam in other than trace amounts, or oily wastes that produce a sheen on the surface of the receiving water.
4. 85% Removal Requirements for BOD₅ and TSS: For each month, the monthly average effluent concentration shall not exceed 15 percent of the monthly average influent concentration.

Percent removal of BOD₅ and TSS shall be reported on the Discharge Monitoring Reports (DMRs). The monthly average percent removal shall be calculated from the arithmetic mean of the influent value and the arithmetic mean of the effluent value for that month. Influent and effluent samples shall be taken over approximately the same time period.

B. Schedule of Compliance.

1. The permittee must achieve compliance with the chlorine limitations of Part 1.A.1. (Table 1) by < 2 years from effective date>. In the interim, the following chlorine effluent limits must be met:

| | |
|------------------------|-----------|
| Average Monthly Limit: | 0.5 mg/l |
| Maximum Daily Limit: | 0.75 mg/l |

2. Until compliance with the effluent limits is achieved, the permittee must submit annual Reports of Progress which outlines the progress made towards reaching the compliance date for chlorine limitations. The 1-year Report of Progress must be submitted by < 12 months after effective date >. At a minimum, the Report of Progress must include:
 1. An assessment of the previous 1 year of effluent data, and a comparison to effluent limitations.
 2. A discussion of progress made towards meeting the effluent limitations.
 3. Further actions and milestones targeted for the upcoming 1 year.

C. Surface Water Monitoring Requirements. The permittee must conduct surface

water monitoring which meets the following requirements:

1. A monitoring station shall be established in the Wilder Ditch Drain above the influence of the facility's discharge, and must be approved by IDEQ.
2. To the extent practicable, surface water sample collection shall occur on the same day as effluent sample collection.
3. Surface water samples shall be grab samples.
4. Monitoring must start after the effective date of the permit and continue for 4 years. Samples shall be analyzed for the parameters listed in Table 2.

| Table 2: Surface Water Monitoring Parameter, and Locations | | |
|---|----------------|------------------------------------|
| Parameter | Units | Upstream Sampling Frequency |
| Temperature | °C | See Note 1 |
| pH | standard units | See Note 1 |
| Total Ammonia as N | mg/L | See Note 1 |
| Total Phosphorous | mg/l | See Note 1 |
| Total Inorganic Nitrogen | mg/l | See Note 1 |
| Dissolved Oxygen | mg/l | See Note 1 |
| 1. A minimum of four (4) samples must be collected each year. Monitoring must occur once during each of the following periods: January - March, April - June, July - September, October - December. | | |

5. **Surface Water Monitoring Report:** Surface water monitoring results must be submitted to EPA with the next NPDES permit renewal application, which is due 180 days prior to the expiration date of the permit. A copy of the results must also be submitted to IDEQ.

At a minimum, the report submitted with the NPDES permit renewal application must include the following:

- a. Dates of sample collection and analyses.
- b. Results of sample analysis.
- c. Location of samples

6. Surface water samples must be collected as long as it is safe to do so. If the surface water samples cannot be collected due to unsafe conditions during a given quarter, an explanation of why the sample was not collected must be included in the surface water monitoring report.
7. Quality assurance/quality control plans for all the monitoring shall be documented in the Quality Assurance Plan required under Part I.D., "Quality Assurance Plan."

D. Operation and Maintenance Plan. In addition to the requirements specified in Section III.E. of this permit (Proper Operation and Maintenance), << **within 180 days of the effective date of this permit. Exact date to be added to final permit**>>, the permittee shall develop and implement an operations and maintenance plan for the wastewater treatment facility. The plan shall be retained on site and made available on request to EPA and IDEQ.

E. Quality Assurance Requirements. The permittee must develop a quality assurance plan (QAP) for all monitoring required by this permit. The plan must be developed and implemented <<**within 180 days of the effective date of this permit. Exact date to be added to final permit**>>. Any existing QAPs may be modified for the requirements under this section.

1. The QAP must be designed to assist in planning for the collection and analysis of effluent and receiving water samples in support of the permit and in explaining data anomalies when they occur.
2. Throughout all sample collection and analysis activities, the permittee must use the EPA-approved QA/QC and chain-of-custody procedures described in:

(1) *EPA Requirements for Quality Assurance Project Plans EPA-QA/R-5* (EPA/240/B-01/003, March 2001). A copy of this document can be found electronically at: <http://www.epa.gov/quality/qs-docs/r5-final.pdf>

(2) *Guidance for Quality Assurance Project Plans EPA-QA/G-5*, (EPA/600/R-98/018, February, 1998). A copy of this document can be found electronically at:
<http://www.epa.gov/r10earth/offices/oea/epaqag5.pdf>

The QAP must be prepared in the form which is specified in these documents.

3. At a minimum, the QAP must include the following:
 - a. Details on the number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements.
 - b. Map(s) indicating the location of each sampling point.
 - c. Qualification and training of personnel.
 - d. Name(s), address(es) and telephone number(s) of the laboratories, used by or proposed to be used by the permittee.
4. The permittee must amend the QAP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAP.
5. Copies of the QAP must be kept on site and made available to EPA and/or IDEQ upon request.

II. MONITORING, RECORDING AND REPORTING REQUIREMENTS

- A. Representative Sampling (Routine and Non-Routine Discharges).** Samples and measurements must be representative of the volume and nature of the monitored discharge.

In order to ensure that the effluent limits set forth in this permit are not violated at times other than when routine samples are taken, the permittee must collect additional samples at the appropriate outfall whenever any discharge occurs that may reasonably be expected to cause or contribute to a violation that is unlikely to be detected by a routine sample. The permittee must analyze the additional samples for those parameters limited in Part I.A. of this permit that are likely to be affected by the discharge.

The permittee must collect such additional samples as soon as the spill, discharge, or bypassed effluent reaches the outfall. The samples must be analyzed in accordance with paragraph II.C (“Monitoring Procedures”). The permittee must

report all additional monitoring in accordance with paragraph II.D (“Additional Monitoring by Permittee”).

B. Reporting of Monitoring Results.

1. **Effluent Monitoring Results:** The permittee must summarize monitoring results each month on the Discharge Monitoring Report (DMR) form (EPA No. 3320-1) or equivalent or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices. The permittee must submit reports monthly, postmarked by the 15th day of the following month. The permittee must sign and certify all DMRs, and all other reports, in accordance with the requirements of Part IV.E. of this permit ("Signatory Requirements").
2. **Surface Water Reporting Requirements:** A surface water monitoring report summarizing each sampling event, as outlined in Part I.B.5, must be submitted to EPA with the next NPDES permit renewal application, which is due 180 days prior to the expiration date of the permit. A copy of the monitoring results must also be submitted to IDEQ.
3. The permittee must submit the legible originals of these documents to:

United States Environmental Protection Agency
Region 10
1200 Sixth Avenue, OCE-133
Seattle, Washington 98101
ATTN: PCS Data Entry Team

Copies should be sent to:

Idaho Department of Environmental Quality
Boise Regional Office
1445 N. Orchard Street
Boise, Idaho 83706-2239

- C. Monitoring Procedures.** Monitoring must be conducted according to test procedures approved under 40 CFR 136 or, in the case of sludge use or disposal, approved under 40 CFR 503, unless other test procedures have been specified in this permit.
- D. Additional Monitoring by Permittee.** If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved

under 40 CFR 136 or, in the case of sludge use or disposal, approved under 40 CFR 136 unless otherwise specified in 40 CFR 503, or as specified in this permit, the permittee must include the results of this monitoring in the calculation and reporting of the data submitted in the DMR or sludge reporting forms specified by the Director.

Upon request by the Director, the permittee must submit results of any other sampling, regardless of the test method used.

E. Records Contents. Records of monitoring information must include:

1. the date, exact place, and time of sampling or measurements;
2. the name(s) of the individual(s) who performed the sampling or measurements;
3. the date(s) analyses were performed;
4. the names of the individual(s) who performed the analyses;
5. the analytical techniques or methods used; and
6. the results of such analyses.

F. Retention of Records. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR 503), the permittee must retain records of all monitoring information, including, all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, copies of DMRs, a copy of the NPDES permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of the Director or Idaho Department of Environmental Quality at any time.

G. Twenty-four Hour Notice of Noncompliance Reporting

1. The permittee must report the following occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances:
 - a. any noncompliance that may endanger health or the environment;
 - b. any unanticipated bypass that exceeds any effluent limitation in the permit (See Part III.F., "Bypass of Treatment Facilities");

- c. any upset that exceeds any effluent limitation in the permit (See Part III.G., "Upset Conditions");
 - d. any violation of a maximum daily or instantaneous maximum discharge limitation for any of the pollutants in Table 1 of Part I.A. ; or
 - e. any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limitation in the permit.
2. The permittee must also provide a written submission within five days of the time that the permittee becomes aware of any event required to be reported under subpart 1, above. The written submission must contain:
- a. a description of the noncompliance and its cause;
 - b. the period of noncompliance, including exact dates and times;
 - c. the estimated time noncompliance is expected to continue if it has not been corrected;
 - d. steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance; and
 - e. if the non compliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.
3. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the NPDES Compliance Hotline in Seattle, Washington, by telephone, (206) 553-1846.
4. Reports must be submitted to the addresses in Part II.B ("Reporting of Monitoring Results").

H. Other Noncompliance Reporting. The permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for Part II.B ("Reporting of Monitoring Results") are submitted. The reports must contain the information listed in Part II.G.2 of this permit ("Twenty-four Hour Notice of Noncompliance Reporting").

- I. Notice of New Introduction of Pollutants.** The permittee must provide notice to the Director and Idaho Department of Environmental Quality of:
1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to Sections 301 or 306 of the Act if it were directly discharging those pollutants; and
 2. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 3. For the purposes of this section, adequate notice must include information on:
 - a. The quality and quantity of effluent to be introduced into the POTW, and
 - b. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- J. Compliance Schedule.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date.

III. COMPLIANCE RESPONSIBILITIES

- A. Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification, or for denial of a permit renewal application.
- B. Penalties for Violations of Permit Conditions**
1. **Civil and Administrative Penalties.** Pursuant to 40 CFR 19 and the Act, any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt

Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$27,500 per day for each violation).

2. **Administrative Penalties.** Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Pursuant to 40 CFR 19 and the Act, administrative penalties for Class I violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$11,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$27,500). Pursuant to 40 CFR 19 and the Act, penalties for Class II violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$11,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$137,500).
3. **Criminal Penalties:**
 - a. **Negligent Violations.** The Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.
 - b. **Knowing Violations.** Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000

per day of violation, or imprisonment of not more than 6 years, or both.

- c. **Knowing Endangerment.** Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
 - d. **False Statements.** The Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- C. Need to Halt or Reduce Activity not a Defense.** It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with this permit.
- D. Duty to Mitigate.** The permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has

a reasonable likelihood of adversely affecting human health or the environment.

E. Proper Operation and Maintenance. The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

F. Bypass of Treatment Facilities

1. Bypass not exceeding limitations. The permittee may allow any bypass to occur that does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2 and 3 of this Part.
2. Notice.
 - a. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it must submit prior notice, to the Director and Idaho Department of Environmental Quality if possible at least 10 days before the date of the bypass.
 - b. Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required under Part II.G ("Twenty-four Hour Notice of Noncompliance Reporting").
3. Prohibition of bypass.
 - a. Bypass is prohibited, and the Director may take enforcement action against the permittee for a bypass, unless:
 - i) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if

adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance; and

iii) The permittee submitted notices as required under paragraph 2 of this Part.

b. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 3.a. of this Part.

G. Upset Conditions

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the permittee meets the requirements of paragraph 2 of this Part. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
2. Conditions necessary for a demonstration of upset. To establish the affirmative defense of upset, the permittee must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - b. The permitted facility was at the time being properly operated;
 - c. The permittee submitted notice of the upset as required under Part II.G, "Twenty-four Hour Notice of Noncompliance Reporting;" and
 - d. The permittee complied with any remedial measures required under Part III.D, "Duty to Mitigate."
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

H. Toxic Pollutants. The permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Act for toxic pollutants and

with standards for sewage sludge use or disposal established under section 405(d) of the Act within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

I. Planned Changes. The permittee must give notice to the Director and Idaho Department of Environmental Quality as soon as possible of any planned physical alterations or additions to the permitted facility whenever:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29(b); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this permit.
3. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application site.

J. Anticipated Noncompliance. The permittee must give advance notice to the Director and Idaho Department of Environmental Quality of any planned changes in the permitted facility or activity that may result in noncompliance with this permit.

IV. GENERAL PROVISIONS

A. Permit Actions. This permit may be modified, revoked and reissued, or terminated for cause as specified in 40 CFR 122.62, 122.64, or 124.5. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

B. Duty to Reapply. If the permittee intends to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. In accordance with 40 CFR 122.21(d), and unless permission for the application to be submitted at a later date has been granted by the Director, the permittee must submit a new application at least 180 days before

the expiration date of this permit.

- C. Duty to Provide Information.** The permittee must furnish to the Director and Idaho Department of Environmental Quality, within the time specified in the request, any information that the Director or Idaho Department of Environmental Quality may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee must also furnish to the Director or Idaho Department of Environmental Quality, upon request, copies of records required to be kept by this permit.
- D. Other Information.** When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or that it submitted incorrect information in a permit application or any report to the Director or Idaho Department of Environmental Quality, it must promptly submit such facts or information.
- E. Signatory Requirements.** All applications, reports or information submitted to the Director and Idaho Department of Environmental Quality must be signed and certified as follows.
1. All permit applications must be signed as follows:
 - a. For a corporation: by a responsible corporate officer.
 - b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively.
 - c. For a municipality, state, federal, or other public agency: by either a principal executive officer or ranking elected official.
 2. All reports required by the permit and other information requested by the Director or Idaho Department of Environmental Quality must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above;
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent

responsibility, or an individual or position having overall responsibility for environmental matters for the company; and

c. The written authorization is submitted to the Director and Idaho Department of Environmental Quality.

3. Changes to authorization. If an authorization under Part IV.E.2 is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part IV.E.2. must be submitted to the Director and Idaho Department of Environmental Quality prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this Part must make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

F. Availability of Reports. In accordance with 40 CFR 2, information submitted to EPA pursuant to this permit may be claimed as confidential by the permittee. In accordance with the Act, permit applications, permits and effluent data are not considered confidential. Any confidentiality claim must be asserted at the time of submission by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice to the permittee. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR 2, Subpart B (Public Information) and 41 Fed. Reg. 36902 through 36924 (September 1, 1976), as amended.

G. Inspection and Entry. The permittee must allow the Director, Idaho Department of Environmental Quality, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

- H. Property Rights.** The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, nor any infringement of state or local laws or regulations.
- I. Transfers.** This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act. (See 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory).
- J. State Laws.** Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Act.
- K. Reopener.** This permit may be reopened to include any applicable standard for sewage sludge use or disposal promulgated under section 405(d) of the Act. The Director may modify or revoke and reissue the permit if the standard for sewage sludge use or disposal is more stringent than any requirements for sludge use or disposal in the permit, or controls a pollutant or practice not limited in the permit.

The Lower Boise River is listed as impaired for sediment, dissolved oxygen, oil and grease, nutrients, bacteria and temperature. If a future TMDL is approved, and includes a wasteload allocation for these parameters in the Wilder WWTP, EPA may reopen this permit to include effluent limitations for these parameters.

V. DEFINITIONS

1. “Act” means the Clean Water Act.
2. “Administrator” means the Administrator of the EPA, or an authorized representative.
3. “Average monthly discharge limitation” means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.
4. “Best Management Practices” (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage areas.
5. “Bypass” means the intentional diversion of waste streams from any portion of a treatment facility.
6. “Daily discharge” means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.
7. “Director” means the Director of the Office of Water and Watersheds, EPA, or an authorized representative.
8. “DMR” means discharge monitoring report.
9. “EPA” means the United States Environmental Protection Agency.
10. “Geometric mean” of “n” quantities is the “nth” root of the product of the quantities. For example the geometric mean of 100, 200 and 300 is $(100 \times 200 \times 300)^{1/3} = 181.7$
11. “Grab” sample is an individual sample collected over a period of time not

exceeding 15 minutes.

12. “IDEQ” means the Idaho Department of Environmental Quality.
13. “Instantaneous Maximum Limit” means the maximum allowable concentration of a pollutant determined from the analysis of any discrete sample collected, independent of the flow rate and the duration of the sampling event.
14. "Maximum daily discharge limitation" means the highest allowable "daily discharge."
15. “POTW” means publicly owned treatment works.
16. “QA/QC” means quality assurance/quality control.
17. “Regional Administrator” means the Regional Administrator of Region 10 of the EPA, or the authorized representative of the Regional Administrator.
18. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
19. “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
20. “8-hour composite” means a combination of at least 3 discrete samples collected at equal time intervals from the same location, over an 8 hour period. The sample aliquots must be collected and stored in accordance with procedures prescribed in the most recent edition of *Standard Methods for the Examination of Water and Wastewater*.

